

1. Complete specifications for the repurified water lines, “Repurified Water Specifications and Drawings”, February 2019 Ed., are on file at the Murfreesboro Water Resources Department Engineering Annex and can also be found online at <https://www.murfreesborotn.gov/DocumentCenter/View/10641/2019-Final-Repurified-Water-Specs-and-Details>
2. Repurified water construction must be in accordance with all MWRD specifications and drawings.
3. Concerning repurified water line construction, restraints such as rods or kickers shall be installed at any change in direction where fittings are required, at all dead-ends, and at any location as directed by the Water Resources Department.
4. Contractor must have a State of Tennessee license, Municipal Utility (MU) classification, to perform work.
5. All main line repurified water taps will be made by the Murfreesboro Water Resources Department.